

TERMS AND CONDITIONS

---

XX. PERIODIC TESTS AND CHECKS

A. Single-phase alternating current meters will be selected for testing each year using a sampling procedure acceptable to the Commission.

B. Self-contained poly-phase meters in service and poly-phase or single-phase meters in service, when used with current transformers, shall be tested in accordance with the American National Standard Code For Electricity Metering (ANSI C12).