

TERMS AND CONDITIONS

XX. PERIODIC TESTS AND CHECKS

A. Single-phase, alternating current meters will be selected for testing each year using a sampling procedure acceptable to the Commission.

B. Self-contained poly-phase meters in service and poly-phase or single-phase meters in service when used with instrument transformers, shall be tested in accordance with the American National Standard Code for Electricity Metering (ANSI C12).